

CITY OF WAVERLY BOARD OF PLUMBING EXAMINERS

May 6, 2005

The City of Waverly Board of Plumbing Examiners held a meeting on May 6, 2005 at 1:00PM in the Administration Conference Room of Waverly City Hall.

Members Present: Burrier, Cousin, Emmert, & Keller

Members Absent: Rodenbeck

Also Present: Bird, Staff

Chair Keller called the meeting to order at 1:15 PM. Emmert made a motion to approve the January 11, 2005 minutes as written, seconded by Burrier.

Ayes: Burrier, Cousin, Emmert, & Keller

Nays: None

Absent: Rodenbeck

Building Official, Bird discussed the differences in test required for licensing of Plumbers. Following the discussion it was decided to not change any of the testing requirements at this time, but prior to adoption of the 2006 Codes, the testing requirements will be reviewed. Bird is to contact Waterloo & Cedar Falls Building Departments to determine if agreement can be reached regarding reciprocity.

Bird asked for clarification on the use of SDR 23.5. Board members clarified that this piping must stop a minimum of 2' outside the building wall. Clarification was also requested regarding the use of SCH 40 PVC under a floor. The current code states that only cast iron may be used. Board members clarified that SCH 40 PVC is an acceptable use under a floor.

With no further business the meeting was then adjourned at 2:15PM by Chair Keller.

Doug Bird, Secretary
City of Waverly Board of Plumbing Examiners

DB:smn